

Self-Inspection Checklist

Compressed Gas Cylinders

Date Inspected _____ Date Completed _____

Checklist	Needs to be Addressed	Completed	Not Applicable
Are cylinders with a water weight capacity over 30 pounds, equipped with means for connecting a valve protector device , or with a collar or recess to protect the valve?			
Are cylinders legibly marked to clearly identify the gas contained?			
Are compressed gas cylinders stored in areas which are protected from external heat sources such as flame impingement, intense radiant heat, electric arcs, or high temperature lines?			
Are cylinders located or stored in areas where they will not be damaged by passing or falling objects or subject to tampering by unauthorized persons?			
Compressed Gas Transportation:			
Are cylinders stored or transported in a manner to prevent them from creating a hazard by tipping, falling or rolling ?			
Are cylinders containing liquefied fuel gas, stored or transported in a position so that the safety relief device is always in direct contact with the vapor space in the cylinder?			
Are valve protectors always placed on cylinders when the cylinders are not in use or connected for use?			
Are all valves closed off before a cylinder is moved , when the cylinder is empty , and at the completion of each job ?			
Are low pressure fuel-gas cylinders checked periodically for corrosion, general distortion, cracks, or any other defect that might indicate a weakness or render it unfit for service?			
Does the periodic check of low pressure fuel-gas cylinders include a close inspection of the cylinders' bottom ?			

This gas cylinder safety checklist is NOT all-inclusive. You should add to it as necessary or skip parts that are not applicable to your company. Carefully consider each item, and refer to OSHA federal health and safety regulations for complete and specific guidelines that may apply to your work environment. This list is typical for general industry, not construction or maritime. Please contact NATIONAL SAFETY COMPLIANCE for any training or safety supplies you may need.